



## Certificate of Analysis Minerals Testing – Water

Certificate No.: 21-814-817-2018

<b>Sender:</b>	
<b>Address for results:</b>	
<b>Date of receiving:</b> 01/05/18	<b>Testing termination date:</b> 31/05/18
<b>FAX:</b>	<b>Phone:</b>
<b>Laboratory No.:</b> 814-817	<b>Sender No.:</b>
<b>Sample description:</b> Water sample tested for a filter	

### Results

Parameters	Units	Result before filtration in SPure filter (dark)	Result after filtration in SPure filter (dark)
Lab. No.		814	817
Arsenic (As)	µg/L	9.4	5.9

**Comments:**

<b>Name of the tester:</b> Amal Hanna Jacob	<b>Signature:</b>
<b>Name of the authorizer:</b> Dr. E. Kalily	<b>Position:</b> Chem. Lab. Manager
<b>Signature:</b>	

**End of certificate**

**Ministry of Health  
Public Health Laboratory  
P.O.Box 99757 Haifa, Israel  
Tel 04-8619705 Fax: 04-8510172**

**Laboratory seal**

The results refer only to the tested sample.

The Israel Authority for Accreditation is not responsible for the results performed by the laboratory, and the accreditation does not certify the tested sample.

It should be to refer to the whole certificate and it's forbidden to copy from it into other certificates.