



Certificate issue date: 04/06/2024

Test Results of Water-Certificate of Analysis 24-779202

Customer	Tipa Tech
Contact person	ברוך זיסר
Address	קיבוץ יסעור ד.נ. משגב
Sampling site	

Telephone	0502611600
Sampled by	Client
Email	ziser@tipatech.co.il
MOH district	

Sampling time & date	20/05/2024 10:00
Delivery time, date& temp'	20/05/24 10:00 6° C
Test time & date	20/05/24 10:00
Order number	שלב ' לגיונלה

Lab number	Sample description	Legionella count
24-779202/001	Contaminated Water	9363 (LP 1)
24-779202/002	Genesis - Lotus	<1
Standard/method		ISO 11731
Units		CFU / 1000 ml
Specification *		
Accreditation/recognition		A B

*** According to Standard 1505-1 שלב ב'**

Accreditation/recognition: -

The institute's quality system complies with ISO/IEC 17025 and follows written SOP

A. The laboratory is authorized to perform the test according to ISO/IEC 17025 by ISRAC requirements

C. The laboratory is certified by the Israeli Ministry of Health to perform the test according to GMP


B. The laboratory is recognized by the Israeli Ministry of Health to perform the test.

(-) no accreditation, no recognition

This certificate is valid only when it is presented in its complete format, and it is not permitted to extract part for inclusion in any other document. The data presented, accurately expresses the results for the sample described above only. The laboratory's standards are traceable to national and international standards. ISRAC is not responsible for the test results conducted by the institute, and the accreditation does not confirm the item tested. I hereby certify that this electronically generated certificate of analysis is authentic.

The use of ISRAC symbol relates to tests/calibrations which are included in the organization scope of accreditation, and performed according to the accreditation rules as detailed in the accreditation certificate.

Waterlab:

Authorized by: Water Lab Manager Oleg Krasnov 

Reviewed by: Dr. Irit Weiser, CEO 

End of certificate of analysis